



**DETAIL A-A**

**NOTES**

1. ALL WELDED CONNECTIONS MUST BE 1/2" FULL STRENGTH WELDS ALONG ENTIRE LENGTH OF THE CONNECTION AND MUST BE IN ACCORDANCE WITH THE REQUIREMENTS OF AWS AND AISC CODES.
2. ALL METAL SURFACES AND WELDED CONNECTIONS MUST BE PAINTED WITH ONE COAT ZINC CHROMATE OR RED LEAD PRIMER (INDUSTRIAL QUALITY). THE SECOND AND FINISHED COAT MUST BE DONE IN ACCORDANCE WITH THE MAG SPECIFICATIONS SECTIONS 530 AND 790. FINISH COAT SHALL BE PERVO 2432 OIL BASED INDUSTRIAL ENAMEL "RWCD TAN" OR APPROVED EQUAL.

LAST UPDATED: 03/06/06

**ROOSEVELT WATER CONSERVATION DISTRICT**

**STEEL GATE**