

Roosevelt Water Conservation District

GENERAL NOTES

1. GENERAL CONDITIONS:
 - A. ALL CONSTRUCTION OF RWCD FACILITIES SHALL CONFORM TO THE LATEST RWCD SPECIFICATIONS (WWW.RWCD.ORG) AND LATEST MAG SPECIFICATIONS.
 - B. THE CONTRACTOR SHALL OBTAIN A PERMIT FROM RWCD BEFORE ANY WORK BEGINS THAT IMPACTS RWCD FACILITIES OR ACCESS TO RWCD FACILITIES.
 - C. AN APPROVED SET OF PLANS SHALL BE ON THE JOB SITE AT ALL TIMES THAT WORK IS IN PROGRESS. DEVIATION FROM THE PLANS SHALL NOT BE ALLOWED WITHOUT AN APPROVED PLAN REVISION FROM THE ENGINEER.
 - D. TRAFFIC CONTROL SHALL BE MAINTAINED IN ACCORDANCE WITH THE MAG SPECIFICATION 401, THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES, AND CURRENT TRAFFIC BARRICADE MANUAL.
 - E. THE CONTRACTOR IS RESPONSIBLE FOR OBTAINING, IF NECESSARY, AN EXCAVATION AND DIRT MOVING PERMIT FROM THE MARICOPA COUNTY ENVIRONMENTAL SERVICES DEPARTMENT AND COMPLYING WITH ITS REQUIREMENTS FOR DUST CONTROL.
 - F. NO ACTIVITY INVOLVING AN RWCD MANHOLE SHALL OCCUR WITHOUT PRIOR AUTHORIZATION BY RWCD. THIS INCLUDES, BUT IS NOT LIMITED TO, REMOVING THE MANHOLE LID, RIM OR ANY DEVICE HOLDING THE MANHOLE LID OR RIM IN PLACE. CONTACT RWCD'S CONSTRUCTION INSPECTOR AT 480.748.6416 TO COORDINATE.
2. LANDSCAPE NOTES:
 - A. TREES TO BE INSTALLED ADJACENT TO ANY RWCD FACILITY WILL BE PLANTED NO CLOSER THAN 6' FROM THE ROOT BALL TO THE EDGE OF RWCD PIPE OR THE EDGE OF ANY OTHER STRUCTURE, E.G. MANHOLE, DELIVERY STRUCTURE. RWCD RESERVES THE RIGHT TO MODIFY THIS CONDITION AT ANY TIME PER OUR DISCRETION. CONTACT RWCD'S CONSTRUCTION INSPECTOR AT 480.748.6416 TO COORDINATE.
 - B. NO LANDSCAPE SPRINKLERS OR WATER EMITTERS ARE PERMITTED WITHIN 15 FEET OF ANY RWCD DELIVERY STRUCTURE.
 - C. THE HOME OWNER'S ASSOCIATION IS RESPONSIBLE TO MAKE REPAIRS TO LANDSCAPING (INCLUDING TREES, GROUND OVER, GRASS, ETC) WHERE IT IS DAMAGED DURING REPAIRS TO RWCD PIPE OR OTHER FACILITIES.
 - D. LANDSCAPE BOULDERS SHALL BE KEPT 15' AWAY FROM THE OUTSIDE OF RWCD MANHOLES, TURNOUT STRUCTURES, HEADWALLS, ETC.
3. CONSTRUCTION SEQUENCE AND REQUIREMENTS:
 - A. ALL CONSTRUCTION ACTIVITIES INVOLVING THE MODIFICATIONS AND/OR REPLACEMENT OF RWCD OWNED FACILITIES SHALL BE BONDED AT A FIGURE APPROVED BY THE GENERAL MANAGER. SUCH BOND SHALL BE MADE TO THE BENEFIT OF RWCD AND WILL NOT BE RELEASED UNTIL SUCH TIMES AS THE GENERAL MANAGER OR OTHER AUTHORIZED INDIVIDUAL HAS APPROVED ALL CONSTRUCTION ACTIVITIES FOR COMPLETENESS AND CORRECTNESS.
 - B. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COORDINATING IRRIGATION DRY-UPS. CONTACT RWCD CONSTRUCTION INSPECTOR AT 480.748.6416 OR 480.988.9586 TO SCHEDULE A DRY-UP.
 - C. THE CONTRACTOR SHALL PROVIDE A COPY OF THE FOLLOWING TO THE RWCD INSPECTOR BEFORE THE PIPE IS INSTALLED.
 - 1) RESULTS OF D-LOAD TEST ON 1% OF THE PIPE LENGTH FOR EACH DAY OF BATCH PRODUCTION.
 - 2) A CONCRETE CYLINDER BREAK ON 1% OF THE PIPE LENGTH FOR EACH DAY OF BATCH PRODUCTION.
 - 3) THE DATE OF PIPE MANUFACTURE AND CLASS OF PIPE SHALL APPEAR ON EVERY LENGTH OF PIPE DELIVERED TO THE JOBSITE. ALL PIPE SHALL HAVE A MINIMUM 14 DAYS OF CURE TIME BEFORE INSTALLATION.
 - D. IT IS THE CONTRACTOR'S RESPONSIBILITY TO LOCATE ALL UTILITIES PRIOR TO EXCAVATION AND AVOID DAMAGE TO SAME. CALL 602.263.1100 FOR BLUE STAKE TWO WORKING DAYS PRIOR TO DIGGING.
 - E. THE CONTRACTOR SHALL ENSURE NO CONSTRUCTION DEBRIS IS ALLOWED TO ENTER ANY RWCD DITCH OR FACILITY DURING CONSTRUCTION.
 - F. RWCD STRUCTURES ARE TO BE POURED MONOLITHICALLY. SHOULD IT BE NECESSARY TO CONSTRUCT AN RWCD STRUCTURE USING MULTIPLE CONCRETE POURS, THE CONTRACTOR WILL BE REQUIRED TO USE AN RWCD APPROVED METHOD OF WATER STOP ON EACH STRUCTURE THAT IS TO BE CONSTRUCTED USING MULTIPLE CONCRETE POURS. CONTACT RWCD'S CONSTRUCTION INSPECTOR AT 480.748.6416 TO COORDINATE.
 - G. THE CONTRACTOR SHALL REPAIR OR REPLACE ANY RWCD FACILITY (HEADWALL, PIPE, DITCH, ACCESS ROADS, ETC.) DAMAGED DURING CONSTRUCTION AS DIRECTED BY THE RWCD INSPECTOR. THE REPAIRED FACILITY SHALL BE AT THE LOCATION, ELEVATION AND GRADES PRIOR TO CONSTRUCTION OR AS DIRECTED.
 - H. RWCD MANHOLES ARE TO BE IDENTIFIED AND PROTECTED AT ALL TIMES BEFORE, DURING AND AFTER CONSTRUCTION. THE CONTRACTOR WILL BE REQUIRED TO INSTALL, AT A MINIMUM, TWO (2) 2X4s VERTICALLY ON OPPOSITE SIDES OF EACH MANHOLE TO PROVIDE IDENTIFICATION OF THE MANHOLE. CONTACT RWCD'S CONSTRUCTION INSPECTOR AT 480.748.6416 TO COORDINATE.

LAST UPDATED: 03/29/07

ROOSEVELT WATER CONSERVATION DISTRICT

RWCD GENERAL NOTES

SHEET 1 OF 2

MINIMUM REQUIRMENTS AND NOTES

GEN NOTE

4. TRENCH EXCAVATION:
 - A. TRENCH EXCAVATION, BACKFILLING AND COMPACTION FOR RWCD FACILITIES SHALL BE PER MAG SPEC SECTION 601, OR AS MODIFIED ON THE PLAN. BACKFILLING SHALL NOT BEGIN ON ANY PIPE UNTIL THE LINE HAS BEEN APPROVED BY RWCD'S INSPECTOR. BEDDING MATERIAL SHALL CONSIST OF ABC APPLIED IN ONE LIFT UP TO THE SPRINGLINE OF THE PIPE (SEE MAG SPEC 601.4.2). A SECOND LIFT OF ABC BACKFILL SHALL BE APPLIED TO 12 INCHES ABOVE THE TOP OF PIPE. COMPACTION OF THE BEDDING MATERIAL SHALL BE BY MAG SPEC 601.4.5. THE TRENCH BACKFILL SHALL BE THOROUGHLY COMPACTED TO THE DENSITIES AND AS DETERMINED BY MAG SPEC 601.4.4, CONTRACTOR MAY SUBSTITUTE ABC SLURRY FOR BACKFILL UP TO SPRINGLINE.
 - B. COMPACTION TESTS SHALL BE PERFORMED AT ALL STRUCTURES AND AT A MINIMUM OF EVERY 300 FEET ALONG THE PIPE, AT LOCATIONS SPECIFIED BY THE RWCD INSPECTOR. A RESPONSIBLE PARTY FOR COMPACTION TESTING SHALL BE PRESENT DURING BACKFILLING OF ALL PIPE AND STRUCTURES. COPIES OF THE COMPACTION TESTS ARE TO BE SUBMITTED TO THE RWCD INSPECTOR AT THE CONCLUSION OF EACH DAY.
5. UTILITY CROSSINGS:
 - A. CALL THE RWCD INSPECTOR, GREG NEW, 480.748.6416 PRIOR TO MAKING THE UTILITY CROSSING. PERMIT MAY BE REQUIRED FOR EACH UTILITY THAT CROSSES RWCD FACILITY.
 - B. PROVIDE 2' CLEARANCE BETWEEN ANY RWCD FACILITY AND ANY NEW UTILITY WHEN CROSSING, EXCEPT TO PROVIDE MINIMUM 4' CLEARANCE BETWEEN ANY RWCD OPEN DITCH AND ANY NEW UTILITY WHEN CROSSING. SUCH UTILITY CROSSINGS SHALL ONLY OCCUR UNDER PIPES AND DITCHES.
 - C. IF USING AN OPEN CUT TRENCH METHOD OF CONSTRUCTION, AS APPROVED BY RWCD, BACKFILL TO THE SPRINGLINE OF THE RWCD PIPE WITH ½ SACK SLURRY WHERE MECHANICAL COMPACTION CANNOT BE ACHIEVED, OR AS DIRECTED BY RWCD INSPECTOR.
 - D. IF ANY EXISTING UTILITY IS FOUND TO HAVE LESS THAN 2 FT OF CLEARANCE TO THE RWCD FACILITIES, THE CONTRACTOR SHALL CONSULT WITH THE RWCD INSPECTOR AND THE OTHER UTILITY COMPANY FOR EVALUATION OF CLEARANCE AND RELOCATION REQUIREMENTS.
 - E. ALL OVERHEAD WIRES THAT SUSPEND OVER THE RWCD RIGHT OF WAY SHALL HAVE 25 FEET MINIMUM OVERHEAD CLEARANCE.
6. RWCD INSPECTION:
 - A. CALL GREG NEW AT RWCD (480.748.6416) FOR RWCD INSPECTIONS. THE CONTRACTOR SHALL COORDINATE DAILY WITH THE RWCD INSPECTOR RELATIVE TO WORK ONGOING THAT DAY AND UPCOMING WORK THAT REQUIRES INSPECTION WITHIN THE NEXT 48 HOURS.
 - B. THE CONTRACTOR SHALL PROVIDE A SAFE TRENCH FOR THE RWCD INSPECTOR TO INSPECT WORK INCLUDING SHORING AND LADDERS.
 - C. CONSTRUCTION STAKING LATH SHALL INCLUDE STATIONING CONSISTENT WITH STATIONING SHOWN ON THE APPROVED IRRIGATION PLANS.
 - D. MANHOLE AND STRUCTURE RIM ELEVATIONS MUST BE VERIFIED DURING THE CONSTRUCTION BY A "HUB" PLACED BY SURVEYORS.
 - E. RWCD MAY REJECT ANY PART OF PORTION OF THE SUBJECT PIPE AT ANY POINT DURING THE INSTALLATION PROCESS AT ITS SOLE DISCRETION. SUCH DETERMINATION WILL BE BASED ON, AMONG OTHER POINTS, CURRENT ASTM STANDARDS FOR THE PIPE.
7. PROJECT ACCEPTANCE:
 - A. THE JOB SITE, AT THE COMPLETION OF THE CONSTRUCTION, SHALL BE CLEANED OF ANY DEBRIS OR SPOIL RESULTING FROM THE CONSTRUCTION INCLUDING REMOVAL OF CONSTRUCTION DEBRIS FROM RWCD DITCHES.
 - B. THE OWNER/DEVELOPER SHALL ACQUIRE PRIOR AUTHORIZATION FROM THE RWCD WATER DEPARTMENT AND RWCD INSPECTOR PRIOR TO PERFORMING AN AS-BUILT SURVEY. MANHOLE LIDS MUST BE TAKEN OFF BY PIPELINE CONTRACTOR. A NO-FEE DRY-UP IS REQUIRED FOR AS-BUILT SURVEY.
 - C. THE OWNER/DEVELOPER SHALL PROVIDE CERTIFIED AS-BUILTS FOR THE LOCATION, ELEVATION AND SIZE OF ALL RWCD FACILITIES FOR RWCD RECORDS PRIOR TO RELEASING THE PROJECT BOND.
8. RWCD GENERAL NOTES:
 - A. RWCD'S GENERAL NOTES ARE SUBJECT TO CHANGE WITHOUT NOTIFICATION AT ANY TIME PER OUR DISCRETION. IT IS THE CONTRACTOR'S RESPONSIBILITY TO ENSURE CONFORMANCE TO THE LATEST RWCD GENERAL NOTES. CONTACT RWCD'S CONSTRUCTION INSPECTOR AT 480.748.6416 OR RWCD'S ENGINEER AT 480.218.8831 TO RECEIVE THE MOST RECENT RWCD GENERAL NOTES.

LAST UPDATED: 10/04/07

Roosevelt Water Conservation District

RWCD GENERAL NOTES

SHEET 2 OF 2

MINIMUM REQUIRMENTS AND NOTES

GEN NOTE